

BOM				
SYM	DESCRIPTION	P/N	ITEM QTY	
1	VALVE,GATE,OSY,NIBCO,FLG,UL/FM,250PSI,6"	23-002-525	1	
2	VALVE,BUTTERFLY,LUG,NIBCO,LD3510-8,6	23-002-435	4	
3	VALVE,CHECK,NIBCO,KW-900-W,6	23-002-225	2	
4	STD FIRE GAUGE SET	808-400369	2	
5	PUMP,A-C,F,4X4X7F,1580,3550,	100-210-039	1	
6	HOSEHEADER,6X4,GROOVE,2.5	100-200-358	1	
7	CNTRLR, FTA1000-AM20B-AM-CTS-X36-X83,20HP	100-300-175	1	
8	LOAD,CENTER,PANELBOARD	GE	1	
9	POWER,PAK,7.5-KVA	80-003-020	1	
10	HEATER, W/ THERMOSTAT, 7.5KW		1	
11	CNTRLR, JOCKEY, FIRE, FTA500N2	100-300-174	1	

NOTES: 1. CUSTOMER PIPING MUST BE SUPPORTED NEAR ALL INTERFACE CONNECTIONS TO ELIMINATE STRAIN. 2. ALL PIPING SUPPORTS ARE NOT SHOWN FOR CLARITY PURPOSES.

ALL POLYMERIC DRAIN LINE PIPING TO THIS LOCATION.
MINIMUM CLEARANCE TO ANY OBSTRUCTION REQUIRED BY THE NATIONAL ELECTRIC CODE.

ELECTRIC CODE. 5. SHIPPING DIMENSIONS: 176 L x 115 W x 121 H. 6. ESTIMATED SHIPPING WEIGHT: 7,600 LBS, ESTIMATED OPERATING WEIGHT: 8,000 LBS. 7. CONDUIT AND SMALL PIPING RUNS TO FOLLOW STRUCTURAL MEMBERS, WHERE POSSIBLE, TO AVOID CREATING TRIP HAZARDS. 8. TO ACHIEVE THE PROPER BUILDING FOUNDATION DESIGN, AN ENGINEER SHALL BE RETAINED WHO IS FAMILIAR WITH LOCAL BUILDING CODES, SOIL CONDITIONS, AND ANCHORING POUNDERMENTS.

CONDITIONS, AND ANCHORING REQUIREMENTS. 9. BASE PLATE SETTING PRIOR TO PIPING: GROUTING PROCEDURES AND FINAL ALIGNMENT MUST BE IN ACCORDANCE WITH THE XYLEM A-C FIRE PUMP INSTRUCTION MANUAL.

10. INSTALL CHECK VALVE WITH HINGE PINS IN THE VERTICAL POSITION. 11. PRESSURE SENSING LINE DRAINS TO BE PIPED TO THE SKID DRAIN MANIFOLD.

ITEMS TO SHIP LOOSE: • HOSE HEADER, (4) 2.5" VALVES AND PIPING. • PRESSURE GAUGES.

ANY TANK PIPING THAT EXCEEDS THE MAXIMUM SHIPPING HEIGHT.

CUSTOMER INTERFACE CONNECTIONS: A. SUCTION: FLANGED, 6", CLASS 150#. B. DISCHARGE: FLANGED, 6", CLASS 150#.

- C. DRAIN: 2", CLASS 150#.
- D. LOAD CENTER: 460V/ 3PH/ 60HZ.

## PAINT SPECIFICATIONS:

PAINT PER XYLEM FLOWTRONEX SPEC FPP-002.

brand DRAWING #: CONFIGUPAC   VG AND THE INFORMATION DEPICTED THEREIN IS THE PF XYLEM. COPIES ARE ISSUED IN STRICT E AND SHALL NOT BE REPRODUCED OR COPIED, OR DRAWING NAME: IN-LINE WITH BUILDING	- BASE PLATE GROUT REQ'D		(10MM) 3/8" CHAMI TOP AND BOTTOM OF PLATE, 30"	
M:   HERNANDEZ   8/7/2012     M:   DALLAS, TX 75220   DATE:     DalLAS, TX 75220   DATE:     NG AND THE INFORMATION DEPICTED THEREIN IS THE PF XYLEM. COPIES ARE ISSUED IN STRICT E AND SHALL NOT BE REPRODUCED OR COPIED, OR   DRAWING NAME:			4 PLCS.	CROSBY #1017516
Image: Drawing with the information depicted therein is the previous struct with building with the information depicted therein is the previous struct with building with the information of the previous struct with building with the information of the previous struct with building with the previous struct with the	PUMP	DALLAS, TX 75220	M. HERNANDE CHK:	EZ 8/7/2012
VITHOUT PRIOR WRITTEN PERMISSION OF XYLEM.	NG AND THE INFORMATIO DF XYLEM. COPIES ARE IS E AND SHALL NOT BE REF E BASIS FOR THE MANUF/	N DEPICTED THEREIN IS SUED IN STRICT RODUCED OR COPIED, ACTURE OR SALE OF	#: THE DRAWING NAME OR IN-LI	E: NE WITH BUILDING